


RADIANT COOLING SYSTEM CLASSIFICATION & BASICS OF SLAB COOLING

CONTENTS




- Radiant cooling systems classification
 - Introduction
 - Key features
- Basics of slab cooling system design
 - Estimation of cooling capacity
 - Basic design (tube length, spacing, diameter)
 - Loop layouts & manifolds
- Installation procedure

RADIANT COOLING SYSTEMS - CLASSIFICATION



RADIANT COOLING SYSTEMS - CLASSIFICATION




Structure integrated systems (Slab, Wall)
Thermally active building system (TABS)

Source: Jingjuan Feng, PhD Thesis, “Design and Control of Hydronic Radiant Cooling Systems”, University of California, Berkeley



Source: Infosys

RADIANT COOLING SYSTEMS - CLASSIFICATION




Panel cooling systems



Source: Jingjuan Feng, PhD Thesis, "Design and Control of Hydronic Radiant Cooling Systems", University of California, Berkeley

RADIANT COOLING SYSTEMS - CLASSIFICATION




Embedded surface system




Source: Jingjuan Feng, PhD Thesis, "Design and Control of Hydronic Radiant Cooling Systems", University of California, Berkeley


RADIANT COOLING SYSTEMS - CLASSIFICATION



Structure integrated systems (Slab, Wall)
Thermally active building system (TABS)




Panel cooling systems



Embedded surface system

STRUCTURE INTEGRATED SYSTEMS: SLAB COOLING




BASICS OF SLAB COOLING SYSTEM DESIGN

RADIANT COOLING – BASICS




- Radiant cooling is often part of a hybrid system that includes conditioning of ventilation air to address internal latent loads (humidity) from occupants and infiltration, plus sensible and latent loads associated with outside ventilation air.
- An actively controlled surface is considered a “radiant system” if at least 50% of the design heat transfer is by thermal radiation (2004 ASHRAE Handbook)


RADIANT SYSTEM SIZING



- D O A S cools the fresh air to lower temperatures to remove the moisture
- Cooled air supply removes some part of the sensible loads




DESIGN PROCEDURE



WHAT IS ACTIVE AREA?

- Surface area available for heat transfer (cooling)
- Cooling capacity must be calculated with active area; not with the ceiling area (particularly for radiant panels)



For slab cooling, active
area 80-95%

Image Source: Ecophit Radiant Ceilings, Germany

RADIANT SURFACE TEMPERATURE



- Objective: Avoid condensation
- Minimum allowable surface temperature is decided w.r.t. dew point temperature

$$T_{surface} \geq T_{dewpoint} + 2^{\circ}C$$

E.g. with 25°C air temperature & 55% RH; the dew point temperature is ~16°C.

$$T_{surface} \geq 18^{\circ}C$$

OPERATIVE TEMPERATURE



$$T_{op} = \frac{h_r T_{MRT} + h_c T_{air}}{h_r + h_c}$$


$$T_{op} \approx \frac{T_{MRT} + T_{air}}{2}$$

The temperature of a uniform isothermal black enclosure in which the occupant exchanges the same amount of heat by radiation and convection as in the actual non-uniform environment

For air velocities of 0.4 m/s (1.3 ft/s) and an MRT of 50°C (122°F) or less, the operative temperature is approximately the average of the air temperature and MRT

RADIANT COOLING – BASICS

Mean Radiant Temperature




The uniform surface temperature of an imaginary black enclosure in which the radiation from the occupant equals the radiant heat transfer in the actual non-uniform enclosure

DETERMINING COOLING CAPACITY

- Cooling capacity of chilled slab:


$$Q = h_{\text{rad+conv}} \times \Delta T \times \text{Active area}$$
- $h_{\text{rad+conv}}$ = Combined Heat transfer coefficient
- ΔT = Operative temperature - ceiling surface temperature

Operative temperature = 25°C




Cooling surface	Combined Heat transfer coefficient $h_{\text{rad+conv}}$ (W/m ² .K)	Allowable surface temperatures (°C)	Capacity per unit chilled surface area (W/m ²)
Slab	8 - 11	18	56 - 77

DESIGN PROCEDURE




ESTIMATING TUBING LENGTH REQUIRED PER ZONE

- Length of the tubing from supply to return ports in a zone is called tubing length.
- Typical tubing diameter ranges from 12.5 to 20 mm (0.5 to 0.75 inch)
- Tube spacing is the distance between two tubes (center to center), typically it ranges from 150 to 450 mm (6-18 inch)
- Tube length per sq. ft. depends on tube spacing, it ranges from 2.2 to 6.6 m/m² (0.67 to 2 ft/ ft²)
- Total tube length = Available surface area x tube length per sq.m.




EXAMPLE FOR FINDING TUBE LENGTH

- Zone area = 500 m²
- Available area = 400 m² (@80%)
- Tube spacing = 150 mm
- Tube length = 6.6 m/m²
- Total tube length = 2625 m



DESIGN PROCEDURE



EXAMPLE FOR FINDING TUBE LENGTH


- Zone area = 500 m²
- Available area = 400 m² (@80%)
- Tube spacing = 150 mm
- Tube length = 6.6 m/m²
- Total tube length = 2625 m

Effects of long single piping layout:

- Higher temperature drop along the piping leads to uneven surface temperature
- High flow rates through pipes leads to higher pressure drop

Solution:

- Dividing the total tube length into multiple loops as suited for zone requirements



SELECTING LOOP LENGTH AND DIAMETER




- Loop length & Tube Diameter
 - Affects temperature drop of the chilled water (important from surface temperature uniformity point of view)
 - Affects pressure drop of the loop (pump energy)

Tube diameter (inch)	Tube diameter (mm)	Tube length (ft)	Tube length (m)	Pressure drop (in WC)
3/8"	9.5	125 - 150	38 - 46	Goal PD < 10 ft (3 m)
1/2"	12.7	250 - 300	76 - 91	
5/8"	15.9	350 - 450	107 - 137	
3/4"	19.1	450 - 500	137 - 152	

Tube length and tube diameter decides Pump Energy and Slab Surface Temperature Uniformity


DETERMINING NUMBER OF LOOPS PER ZONE

- No of loops = total tube length / single loop length




- No of loops depends on zone size, individual loop lengths and tube diameter
E.g. 16 mm tube diameter & 107 m tube length, No. of loops ~ 25


DESIGN PROCEDURE



Loop layouts arrangements





For uniform load
(Counter flow spiral conduit pattern)



For varying load within the space (Solar gains near façade)
(Serpentine conduit pattern)


Loop layouts arrangements

Even Temperature distribution



Hot water

Chilled water




Hot water

Chilled water


Uneven Temperature distribution

DESIGN PROCEDURE




MULTIPLE ZONES – SINGLE MANIFOLD

Chilled water distributed from manifold to different circuit / loops




LOOP LAYOUTS FOR LARGE ZONES



MULTIPLE ZONES – MULTIPLE MANIFOLDS




Manifolds



TITLE	DESCRIPTION
Circle Radiators	Radiant Heating Layout - First Floor
DRAWN BY:	DATE:
Advanced Radiant Design	10/01/2011

USE OF CONTROLS TO AVOID CONDENSATION



INSTALLATION PROCEDURE



- Laying pipe layouts
- Pressure testing
- Connecting radiant cooling pipes to chiller
- Commissioning the system

INSTALLATION PROCEDURE



INSTALLATION PROCEDURE



INSTALLATION PROCEDURE



RADIANT SLAB COOLING – INDIA



Infosys – Software Development Block -1,
Hyderabad



Indian Institute of Tropical
Meteorology (IITM), Pune

THANK YOU